



3990 U.S. 311 Hwy N P.O. Box 160  
Pine Hall, NC 27042  
Phone: (336) 427-6611  
Fax: (336) 427-8120

## Product Certification Sheet

**KobeWieland Copper Products, LLC** Manufactures tube to meet all requirements of the current American Society of Testing and Materials (ASTM) specification for the following:

---

---

**SEAMLESS COPPER WATER TUBE – TYPE K, L, M**  
**Size Range ¼" to 3"**

**ASTM B-88**

*Copper tube (Alloy 12200) has been evaluated by Underwriters Laboratories, Inc. To ANSI/NSF Standard 61 for use in drinking water supplies of pH 6.5 and above. Drinking water supplies which are less than pH 6.5 may require corrosion control to limit leaching of copper into the drinking water.*

*Copper tube has been NSF classified by Underwriters Laboratories, Inc. only to ensure that specific analyzed samples met regulatory requirements.*

---

---

**SEAMLESS COPPER TUBE FOR MEDICAL GAS SYSTEMS**

**ASTM B-819**

*(Manufactured tubes are plugged and charged with nitrogen following the cleaning operation)*

**SEAMLESS COPPER TUBE FOR AIR CONDITIONING AND REFRIGERATION FIELD SERVICE**

**ASTM B-280**

*(Manufactured straight length hard tubes are plugged and charged with nitrogen following the cleaning operation)*

*Tubes are manufactured to the cleanliness requirements of 0.0035 g/ft<sup>2</sup> maximum as required by B-280/B-819.*

---

---

**Copper Drainage Tube (DWV)**

**ASTM B-306**

---

---

All material incised "KWCP" is manufactured in the United States.

Chris Gentry  
QC Laboratory Teamleader  
Technical Services Phone (336) 427 – 6611 Ext. 2173  
Technical Services Fax (336) 427 – 8120

Issued: August 18, 2009